

PFAS Test Results Report

Waterworks Name: NCSA - WINTERGREEN

PWS ID: VA2125910

Collection Date: 6/9/2026

Report Date: 6/29/2026

Program ID: 1174

Report Prepared by TruePani Inc. as part of the
Virginia Department of Health Office of Drinking
Water (VDH ODW) PFAS Testing Program

Entry Point(s) Information

Entry Point ID	Sampling Point ID	Location	Photo
EP001	EP001	EP DEVILS KNOB WELLS	
EP016	EP016	WELL 16 ENTRY POINT	
EP017	EP017	WELL 17 ENTRY POINT	

Results Interpretation

Regulatory Thresholds

Compound	Maximum Contaminant Level (MCL)	Trigger Level	Practical Quantitation Level (PQL)
PFOA	4.0 ppt	2.0 ppt	4.0 ppt
PFOS	4.0 ppt	2.0 ppt	4.0 ppt
PFNA	10 ppt	5 ppt	4.0 ppt
PFHxS	10 ppt	5 ppt	3.0 ppt
HFPO-DA	10 ppt	5 ppt	5.0 ppt
Hazard Index	1 (unitless)	0.5 (unitless)	N/A

Key Terms	
Maximum Contaminant Level (MCL)	The highest level of a PFAS contaminant that is allowed in drinking water under federal regulations. MCLs must be achieved by April 2029. Compliance with a PFAS MCL is typically determined using a running annual average of monitoring results, rather than a single sample result.
Trigger Level	The trigger levels are used to determine a system's monitoring frequency after April 2027 and are set at one-half of the MCLs for regulated PFAS.
Practical Quantitation Level (PQL)	The PQL is defined as the lowest concentration of a contaminant that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operating conditions. The PQLs are used for the MCL compliance determination after Arpil 2027.
Hazard Index (HI)	The Hazard Index is an approach that determines the health concerns associated with mixtures of certain PFAS in finished drinking water. Low levels of multiple PFAS that individually would not likely result in adverse health effects may pose health concerns when combined in a mixture. The HI maximum contaminant level (MCL) represents the maximum level for mixtures of PFHxS, PFNA, HFPO-DA, and PFBS allowed in water delivered by a public water system.
Method Reporting Level (MRL)	The lowest concentration that a laboratory can reliably quantify with acceptable precision and accuracy.

NCSA - WINTERGREEN (VA2125910) Results

Program ID: 1174

Entry Point ID	Location	PFOA Result	PFOA MRL	PFOS Result	PFOS MRL	PFNA Result	HFPO-DA Result	PFHxS Result	Hazard Index
EP001	EP DEVILS KNOB WELLS	<0.7 ppt PASS	2.0	0.5 ppt PASS	2.0	<0.5 ppt PASS	<0.4 ppt PASS	<0.4 ppt PASS	0.0004 ppt PASS
EP016	WELL 16 ENTRY POINT	<0.7 ppt PASS	2.0	0.8 ppt PASS	2.0	<0.5 ppt PASS	<0.4 ppt PASS	<0.4 ppt PASS	0.001 ppt PASS
EP017	WELL 17 ENTRY POINT	<0.7 ppt PASS	2.0	0.9 ppt PASS	2.0	<0.5 ppt PASS	<0.4 ppt PASS	<0.4 ppt PASS	0.0004 ppt PASS



Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

June 29, 2026

Sam Becker
TruePani, Inc
3915 Beryl Rd #125
Raleigh, NC 27607

RE: VA2125910

Dear Sam Becker:

Please find enclosed the analytical results for the **6** sample(s) the laboratory received on **6/10/26 10:00 am** and logged in under work order **JF02186**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in cursive script that reads 'Janet Clutters'.

Janet Clutters
Project Manager
(309) 692-9688 x1743
janet.clutters@pacelabs.com



ANALYTICAL RESULTS

Sample: JF02186-01

Name: 1174-1

Alias: EP001

Reg ID: VA2125910

Sampled: 06/09/26 08:40

Received: 06/10/26 10:00

Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Semivolatile Organics - PFAS - PIA									
PFBA	< 0.6	ng/L	U	1	0.6	2.0	06/18/26 04:28	EJB	EPA 533
PFMPA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:28	EJB	EPA 533
PFPeA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
PFBS	0.7	ng/L	J	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
PFMBA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
PFEESA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
HFPO-DA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
NFDHA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:28	EJB	EPA 533
4:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:28	EJB	EPA 533
PFHxS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
PFHpA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
PFHxA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
ADONA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:28	EJB	EPA 533
PFPeS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
6:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:28	EJB	EPA 533
PFOA	< 0.7	ng/L	U	1	0.7	2.0	06/18/26 04:28	EJB	EPA 533
PFHpS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:28	EJB	EPA 533
PFOS	0.5	ng/L	J	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
PFNA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:28	EJB	EPA 533
9CI-PF3ONS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
8:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:28	EJB	EPA 533
PFDA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:28	EJB	EPA 533
PFUnA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
11CI-PF3OUdS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:28	EJB	EPA 533
PFDaA	< 0.6	ng/L	U	1	0.6	2.0	06/18/26 04:28	EJB	EPA 533
Surrogate: 13C4-PFBA-SURR	92 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C5-PFPeA-SURR	98 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C3-PFBS-SURR	90 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C2-4:2FTS-SURR	102 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C5-PFHxA-SURR	83 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C3-HFPOA-DA-SURR	83 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C4-PFHpA-SURR	84 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C3-PFHxS-SURR	88 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C2-6:2FTS-SURR	98 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C8-PFOA-SURR	90 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C9-PFNA-SURR	85 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C8-PFOS-SURR	86 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C2-8:2FTS-SURR	87 %	50-200					06/18/26 04:28	EJB	EPA 533



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: JF02186-01

Name: 1174-1

Alias: EP001

Reg ID: VA2125910

Sampled: 06/09/26 08:40

Received: 06/10/26 10:00

Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Surrogate: 13C6-PFDA-SURR	83 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C7-PFUnA-SURR	78 %	50-200					06/18/26 04:28	EJB	EPA 533
Surrogate: 13C2-PFDoA-SURR	76 %	50-200					06/18/26 04:28	EJB	EPA 533



ANALYTICAL RESULTS

Sample: JF02186-02

Name: FRB-1174-1

Alias: EP001

Reg ID: VA2125910

Sampled: 06/09/26 08:40

Received: 06/10/26 10:00

Matrix: Water - Field Blank

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Semivolatile Organics - PFAS - PIA									
PFBA	< 0.6	ng/L	U	1	0.6	2.0	06/24/26 00:53	EJB	EPA 533
PFMPA	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 00:53	EJB	EPA 533
PFPeA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
PFBS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
PFMBA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
PFEESA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
HFPO-DA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
NFDHA	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 00:53	EJB	EPA 533
4:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 00:53	EJB	EPA 533
PFHxS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
PFHpA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
PFHxA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
ADONA	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 00:53	EJB	EPA 533
PFPeS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
6:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 00:53	EJB	EPA 533
PFOA	< 0.7	ng/L	U	1	0.7	2.0	06/24/26 00:53	EJB	EPA 533
PFHpS	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 00:53	EJB	EPA 533
PFOS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
PFNA	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 00:53	EJB	EPA 533
9CI-PF3ONS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
8:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 00:53	EJB	EPA 533
PFDA	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 00:53	EJB	EPA 533
PFUnA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
11CI-PF3OUdS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 00:53	EJB	EPA 533
PFDoA	< 0.6	ng/L	U	1	0.6	2.0	06/24/26 00:53	EJB	EPA 533
Surrogate: 13C4-PFBA-SURR	87 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C5-PFPeA-SURR	89 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C3-PFBS-SURR	91 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C2-4:2FTS-SURR	88 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C5-PFHxA-SURR	79 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C3-HFPOA-DA-SURR	83 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C4-PFHpA-SURR	85 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C3-PFHxS-SURR	93 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C2-6:2FTS-SURR	86 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C8-PFOA-SURR	84 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C9-PFNA-SURR	83 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C8-PFOS-SURR	92 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C2-8:2FTS-SURR	88 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C6-PFDA-SURR	84 %	50-200					06/24/26 00:53	EJB	EPA 533



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: JF02186-02

Name: FRB-1174-1

Alias: EP001

Reg ID: VA2125910

Sampled: 06/09/26 08:40

Received: 06/10/26 10:00

Matrix: Water - Field Blank

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Surrogate: 13C7-PFUnA-SURR	90 %	50-200					06/24/26 00:53	EJB	EPA 533
Surrogate: 13C2-PFDoA-SURR	90 %	50-200					06/24/26 00:53	EJB	EPA 533



ANALYTICAL RESULTS

Sample: JF02186-03

Name: 1174-2

Alias: EP016

Reg ID: VA2125910

Sampled: 06/09/26 08:55

Received: 06/10/26 10:00

Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Semivolatile Organics - PFAS - PIA									
PFBA	< 0.6	ng/L	U	1	0.6	2.0	06/18/26 04:52	EJB	EPA 533
PFMPA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:52	EJB	EPA 533
PFPeA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
PFBS	2.3	ng/L		1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
PFMBA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
PFEESA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
HFPO-DA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
NFDHA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:52	EJB	EPA 533
4:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:52	EJB	EPA 533
PFHxS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
PFHpA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
PFHxA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
ADONA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:52	EJB	EPA 533
PFPeS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
6:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:52	EJB	EPA 533
PFOA	< 0.7	ng/L	U	1	0.7	2.0	06/18/26 04:52	EJB	EPA 533
PFHpS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:52	EJB	EPA 533
PFOS	0.8	ng/L	J	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
PFNA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:52	EJB	EPA 533
9CI-PF3ONS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
8:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:52	EJB	EPA 533
PFDA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 04:52	EJB	EPA 533
PFUnA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
11CI-PF3OUdS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 04:52	EJB	EPA 533
PFDoA	< 0.6	ng/L	U	1	0.6	2.0	06/18/26 04:52	EJB	EPA 533
Surrogate: 13C4-PFBA-SURR	94 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C5-PFPeA-SURR	94 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C3-PFBS-SURR	94 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C2-4:2FTS-SURR	98 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C5-PFHxA-SURR	85 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C3-HFPOA-DA-SURR	82 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C4-PFHpA-SURR	87 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C3-PFHxS-SURR	94 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C2-6:2FTS-SURR	107 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C8-PFOA-SURR	93 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C9-PFNA-SURR	89 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C8-PFOS-SURR	92 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C2-8:2FTS-SURR	93 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C6-PFDA-SURR	83 %	50-200					06/18/26 04:52	EJB	EPA 533



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: JF02186-03

Name: 1174-2

Alias: EP016

Reg ID: VA2125910

Sampled: 06/09/26 08:55

Received: 06/10/26 10:00

Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Surrogate: 13C7-PFUnA-SURR	74 %	50-200					06/18/26 04:52	EJB	EPA 533
Surrogate: 13C2-PFDoA-SURR	74 %	50-200					06/18/26 04:52	EJB	EPA 533



ANALYTICAL RESULTS

Sample: JF02186-04

Name: FRB-1174-2

Alias: EP016

Reg ID: VA2125910

Sampled: 06/09/26 08:55

Received: 06/10/26 10:00

Matrix: Water - Field Blank

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Semivolatile Organics - PFAS - PIA									
PFBA	< 0.7	ng/L	U	1	0.7	2.1	06/24/26 01:17	EJB	EPA 533
PFMPA	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
PFPeA	< 0.4	ng/L	U	1	0.4	2.1	06/24/26 01:17	EJB	EPA 533
PFBS	< 0.4	ng/L	U	1	0.4	2.1	06/24/26 01:17	EJB	EPA 533
PFMBA	< 0.4	ng/L	U	1	0.4	2.1	06/24/26 01:17	EJB	EPA 533
PFEESA	< 0.4	ng/L	U	1	0.4	2.1	06/24/26 01:17	EJB	EPA 533
HFPO-DA	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
NFDHA	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
4:2 FTS	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
PFHxS	< 0.4	ng/L	U	1	0.4	2.1	06/24/26 01:17	EJB	EPA 533
PFHpA	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
PFHxA	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
ADONA	< 0.6	ng/L	U	1	0.6	2.1	06/24/26 01:17	EJB	EPA 533
PFPeS	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
6:2 FTS	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
PFOA	< 0.7	ng/L	U	1	0.7	2.1	06/24/26 01:17	EJB	EPA 533
PFHpS	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
PFOS	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
PFNA	< 0.6	ng/L	U	1	0.6	2.1	06/24/26 01:17	EJB	EPA 533
9CI-PF3ONS	< 0.4	ng/L	U	1	0.4	2.1	06/24/26 01:17	EJB	EPA 533
8:2 FTS	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
PFDA	< 0.5	ng/L	U	1	0.5	2.1	06/24/26 01:17	EJB	EPA 533
PFUnA	< 0.4	ng/L	U	1	0.4	2.1	06/24/26 01:17	EJB	EPA 533
11CI-PF3OUdS	< 0.4	ng/L	U	1	0.4	2.1	06/24/26 01:17	EJB	EPA 533
PFDoA	< 0.7	ng/L	U	1	0.7	2.1	06/24/26 01:17	EJB	EPA 533
Surrogate: 13C4-PFBA-SURR	89 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C5-PFPeA-SURR	91 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C3-PFBS-SURR	92 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C2-4:2FTS-SURR	91 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C5-PFHxA-SURR	79 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C3-HFPOA-DA-SURR	85 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C4-PFHpA-SURR	90 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C3-PFHxS-SURR	93 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C2-6:2FTS-SURR	88 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C8-PFOA-SURR	87 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C9-PFNA-SURR	88 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C8-PFOS-SURR	90 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C2-8:2FTS-SURR	93 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C6-PFDA-SURR	89 %	50-200					06/24/26 01:17	EJB	EPA 533



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: JF02186-04

Name: FRB-1174-2

Alias: EP016

Reg ID: VA2125910

Sampled: 06/09/26 08:55

Received: 06/10/26 10:00

Matrix: Water - Field Blank

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Surrogate: 13C7-PFUnA-SURR	94 %	50-200					06/24/26 01:17	EJB	EPA 533
Surrogate: 13C2-PFDoA-SURR	94 %	50-200					06/24/26 01:17	EJB	EPA 533



ANALYTICAL RESULTS

Sample: JF02186-05

Name: 1174-3

Alias: EP017

Reg ID: VA2125910

Sampled: 06/09/26 09:15

Received: 06/10/26 10:00

Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Semivolatile Organics - PFAS - PIA									
PFBA	0.9	ng/L	J	1	0.6	2.0	06/18/26 05:15	EJB	EPA 533
PFMPA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 05:15	EJB	EPA 533
PFPeA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
PFBS	0.8	ng/L	J	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
PFMBA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
PFEESA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
HFPO-DA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
NFDHA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 05:15	EJB	EPA 533
4:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 05:15	EJB	EPA 533
PFHxS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
PFHpA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
PFHxA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
ADONA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 05:15	EJB	EPA 533
PFPeS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
6:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 05:15	EJB	EPA 533
PFOA	< 0.7	ng/L	U	1	0.7	2.0	06/18/26 05:15	EJB	EPA 533
PFHpS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 05:15	EJB	EPA 533
PFOS	0.9	ng/L	J	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
PFNA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 05:15	EJB	EPA 533
9CI-PF3ONS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
8:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 05:15	EJB	EPA 533
PFDA	< 0.5	ng/L	U	1	0.5	2.0	06/18/26 05:15	EJB	EPA 533
PFUnA	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
11CI-PF3OUdS	< 0.4	ng/L	U	1	0.4	2.0	06/18/26 05:15	EJB	EPA 533
PFDaA	< 0.6	ng/L	U	1	0.6	2.0	06/18/26 05:15	EJB	EPA 533
Surrogate: 13C4-PFBA-SURR	93 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C5-PFPeA-SURR	101 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C3-PFBS-SURR	91 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C2-4:2FTS-SURR	108 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C5-PFHxA-SURR	89 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C3-HFPOA-DA-SURR	82 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C4-PFHpA-SURR	88 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C3-PFHxS-SURR	91 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C2-6:2FTS-SURR	110 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C8-PFOA-SURR	90 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C9-PFNA-SURR	87 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C8-PFOS-SURR	88 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C2-8:2FTS-SURR	94 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C6-PFDA-SURR	81 %	50-200					06/18/26 05:15	EJB	EPA 533



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: JF02186-05

Name: 1174-3

Alias: EP017

Reg ID: VA2125910

Sampled: 06/09/26 09:15

Received: 06/10/26 10:00

Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Surrogate: 13C7-PFUnA-SURR	74 %	50-200					06/18/26 05:15	EJB	EPA 533
Surrogate: 13C2-PFDoA-SURR	72 %	50-200					06/18/26 05:15	EJB	EPA 533



ANALYTICAL RESULTS

Sample: JF02186-06

Name: FRB-1174-3

Alias: EP017

Reg ID: VA2125910

Sampled: 06/09/26 09:15

Received: 06/10/26 10:00

Matrix: Water - Field Blank

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Semivolatile Organics - PFAS - PIA									
PFBA	< 0.6	ng/L	U	1	0.6	2.0	06/24/26 01:40	EJB	EPA 533
PFMPA	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 01:40	EJB	EPA 533
PFPeA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
PFBS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
PFMBA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
PFEESA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
HFPO-DA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
NFDHA	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 01:40	EJB	EPA 533
4:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 01:40	EJB	EPA 533
PFHxS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
PFHpA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
PFHxA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
ADONA	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 01:40	EJB	EPA 533
PFPeS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
6:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 01:40	EJB	EPA 533
PFOA	< 0.7	ng/L	U	1	0.7	2.0	06/24/26 01:40	EJB	EPA 533
PFHpS	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 01:40	EJB	EPA 533
PFOS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
PFNA	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 01:40	EJB	EPA 533
9CI-PF3ONS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
8:2 FTS	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 01:40	EJB	EPA 533
PFDA	< 0.5	ng/L	U	1	0.5	2.0	06/24/26 01:40	EJB	EPA 533
PFUnA	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
11CI-PF3OUdS	< 0.4	ng/L	U	1	0.4	2.0	06/24/26 01:40	EJB	EPA 533
PFDoA	< 0.6	ng/L	U	1	0.6	2.0	06/24/26 01:40	EJB	EPA 533
Surrogate: 13C4-PFBA-SURR	89 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C5-PFPeA-SURR	96 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C3-PFBS-SURR	93 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C2-4:2FTS-SURR	98 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C5-PFHxA-SURR	83 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C3-HFPOA-DA-SURR	90 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C4-PFHpA-SURR	88 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C3-PFHxS-SURR	94 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C2-6:2FTS-SURR	89 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C8-PFOA-SURR	84 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C9-PFNA-SURR	85 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C8-PFOS-SURR	91 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C2-8:2FTS-SURR	92 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C6-PFDA-SURR	88 %	50-200					06/24/26 01:40	EJB	EPA 533



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: JF02186-06

Name: FRB-1174-3

Alias: EP017

Reg ID: VA2125910

Sampled: 06/09/26 09:15

Received: 06/10/26 10:00

Matrix: Water - Field Blank

Parameter	Result	Unit	Qualifier	Dilution	MDL	MRL	Analyzed	Analyst	Method
Surrogate: 13C7-PFUnA-SURR	91 %	50-200					06/24/26 01:40	EJB	EPA 533
Surrogate: 13C2-PFDoA-SURR	92 %	50-200					06/24/26 01:40	EJB	EPA 533



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Qualifiers

- J Estimated value; value between the Method Detection Limit and Method Reporting Limit.
- U Parameter was analyzed for, but not detected above the reporting limit.

Certified by: Janet Clutters, Project Manager



CHAIN-OF-CUSTODY PFAS / Analytical Request Document

Page 1 of 1

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A: Client Information
 Company: TRUEPANI, INC
 Email: sam@truepani.com
 Phone: (865) 346-6737

Section B: Project Information
 Report To: vapfas@truepani.com
 PWS ID: VA2125910
 PWS Name: NCSA - WINTERGREEN

Section C: Invoice Information
 Attention: TruePani ACCOUNTS PAYABLE
 Company Address: 3915 Beryl Road #125 Raleigh, NC 27607
 Pace Project Manager: janet.clutters@pacelabs.com

Regulatory Agency:
 Virginia Department of Health Office of
 Drinking Water
 Used for Compliance?
 Yes (DW NPDWR PFAS)

Y = Yes Analyze
 H = Hold

*All samples preserved with Ammonium Acetate

Entry Point Samples

Sample ID	Facility ID/EP ID	Sampling Point ID	Entry Point Location	Matrix	Sample Type	Sample Date	Sample Time	# of Containers	Analysis: 533 PFAS	Comments
1174-1	EP001	EP001	EP DEVILS KNOB WELLS	DW	Grab	6/9/2026	6:40 AM / PM	3	Y	
1174-2	EP016	EP016	WELL 16 ENTRY POINT	DW	Grab	6/9/2026	8:55 AM / PM	3	Y	
1174-3	EP017	EP017	WELL 17 ENTRY POINT	DW	Grab	6/9/2026	9:15 AM / PM	3	Y	

Field Reagent Blank (FRB) Samples

Sample ID	Facility ID/EP ID	Sampling Point ID	Entry Point Location	Matrix	Sample Type	Sample Date	Sample Time	# of Containers	Analysis: 533- FRB	Comments
FRB-1174-1	EP001	EP001	EP DEVILS KNOB WELLS	DW	Grab	6/9/2026	6:40 AM / PM	2	H	
FRB-1174-2	EP016	EP016	WELL 16 ENTRY POINT	DW	Grab	6/9/2026	8:55 AM / PM	2	H	
FRB-1174-3	EP017	EP017	WELL 17 ENTRY POINT	DW	Grab	6/9/2026	9:15 AM / PM	2	H	

IR Gun # 18 Correction Factor (Deg C) +0.1
 Observed Temp (Deg C) 0.5 Corrected Temp (Deg C) 0.6
 Delivery Method: FedEx UPS Walk-in USPS Other

Field Duplicate Samples

Sample ID	Facility ID/EP ID	Sampling Point ID	Entry Point Location	Matrix	Sample Type	Sample Date	Sample Time	# of Containers	Analysis: 533 PFAS	Comments
-----------	-------------------	-------------------	----------------------	--------	-------------	-------------	-------------	-----------------	--------------------	----------

DATE AND TIME: 6/9/26 4:00pm
 ACCEPTED BY: *Sophia Lippert*
 DATE AND TIME: 6/10/26 10:00
 SAMPLER NAME AND SIGNATURE: *Alan Peters*
 Date Signed: 6/9/26

SAMPLE CONDITIONS (Lab Use)
 TEMP (C):
 RECEIVED ON ICE (Y/N):
 Custody Sealed Cooler (Y/N):
 Samples Intact (Y/N):
 Samples Meet NPDWR PFAS Requirements (Y/N):

ENV-FRM-PEOR-0098 v05_Sample Condition Upon Receipt

Client Name: TruePani Work Order #: JF02186 Completed by / Date: SL6/10/26

Custody seal on cooler/box present and seal intact:	☐ Yes ☐ No ☒ N/A
Chain of Custody (CoC) Present:	☒ Yes ☐ No
CoC is Legible:	☒ Yes ☐ No
Sampler Name Present on CoC:	☒ Yes ☐ No
Sampler Signature Present on CoC:	☒ Yes ☐ No
Sample Collection Date Present on CoC:	☒ Yes ☐ No
Sample Collection Time Present on CoC:	☐ Yes ☐ No
CoC Relinquished by Client:	☒ Yes ☐ No
Unique Sample ID's Present on CoC:	☒ Yes ☐ No
CoC and Sample Container Labels Match:	☐ Yes ☐ No
Sample chilling process started prior to receipt: If yes, what type of ice:	☒ Yes ☐ No ☐ N/A ☒ Wet ☐ Blue
Samples received within temperature compliance: ($\leq 6^{\circ}\text{C}$, but above freezing or received same day collected and chill process started prior to receipt)	☒ Yes ☐ No ☐ N/A
Container(s) Received Intact:	☒ Yes ☐ No
Containers Received Labeled and Labels are Legible:	☒ Yes ☐ No
Appropriate Bottles Received for Analysis Requested:	☐ Yes ☐ No
Sufficient Sample Volume Received:	☒ Yes ☐ No
USDA Regulated Soil: Country of Origin: _____ State of Origin: _____	☐ Yes ☐ No ☒ N/A
Trip Blank(s) Received: If present, are they Listed on CoC:	☐ Yes ☐ No ☒ N/A ☐ Yes ☐ No
VOA vials are free of any headspace larger than pea sized bubble (>6mm) – Applies to methods 8260, 624, 524.2 - including THM vials If headspace is present, note sample ID and # of vials	☐ Yes ☐ No ☒ N/A
All (Non-Field) Analysis Received Within Hold Times:	☒ Yes ☐ No
Rush Turn Around Time Requested or Time Sensitive Analysis:	☐ Yes ☒ No
Short Hold Time Analysis (48 Hours or Less):	☐ Yes ☒ No

Client Notification/ Resolution:

If checked, please see attached form for additional comments ☐

Person Contacted: _____ Date/Time: _____

Comments/ Resolution: _____

PM Review is documented electronically in LIMS. By releasing the project, the PM acknowledges they have reviewed the sample.

Qualtrax ID: 296090

Effective Date: 04/29/25

Page 1 of 1

Pace® Analytical Services, LLC (PAS)

Page 16 of 18

WORK ORDER #:

JF02186

INITIALS:

SL

Drinking Water Bottle Receipt Form

SOC (Synthetic Organic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
M504	EDB & DBCP	C, V, 40 ml, Na2S2O3	3								
M504 Trip Blank	Trip Blank	C, V, 40 ml, Na2S2O3	2								
M505 (subcontract)	Toxaphene	C, V, 40 ml, Na2S2O3	3								
M515.3/548	Chlorinated Acids/Endothal	A, G, 500 ml, Na2S2O3	2								
M525.3	Semi-Volatiles	A, G, 1000 ml, ASCB, EDTA, KH2CIT	3								
M531	Carbamates	A, V, 60 ml, Na2S2O3 + MCAA	1								
M549.2	Diquat	A, P, 1000 ml, Na2S2O3 + H2SO4	1								
M550	Benzo(a)Pyrene	A, G, 1000 ml, Na2S2O3 + HCl	3								
*M547	Glyphosate	A, V, 60 ml, Na2S2O3	1								
*M547 Trip Blank	Trip Blank	A, V, 60 ml, Na2S2O3	1								

**SOC_W_GLPHOS" & "SOC_IDPH_GROUP A" ONLY

VOC (Volatile Organic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
M524.2	Regulated Volatile	C, V, 40 ml, ASCB + HCl	3								
M524.2 Trip Blank	Trip Blank	C, V, 40 ml, HCl	3								

IOC (Inorganic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
*300.0 SO4 & Fluoride Probe	Sulfate by IC/Fluoride Probe	P, 500 ml, Total	1								
**Metals - As, Ba, Be, Cd, Cr, Fe, Hg, Mn, Na, Ni, Sb, Se, Ti, Zn & Turb Check	Metals	P, 250 ml, HNO3, Total	1								
CN-T Kelada DW	Cyanide Total	P, 250 ml, NaOH	1								

*Excluded from "IOC IDPH SHORT LIST"

**Excluded Fe, Mn, Na, Ni & Zn from "IOC IDPH SHORT LIST" Fe, Mn, Na, Ni & Zn

THM/HAA

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
THM M524	Trihalomethane	C, V, 40 ml, Na2S2O3	4								
HAA M552	Haloacetic Acid	A, V, 60 ML NH4CL	4								

TOC

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
TOC	Total Organic Carbon	A, V, 40 ml, H2SO4	3								

Chlorite/Bromate

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
Bromate (Subcontract)	Bromate	P, 100 ml, EDA	1								
Chlorite (Subcontract)	Chlorite	P, 100 ml, EDA	1								

Lead/Copper

Method	Description	Bottle Type	Qty
Lead/Copper	Lead Copper	P, 1000ml LC	
School Lead	Lead	P, 250ml LC	

PFAS

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
M533	PFAS	533, P, 250mL, C2H7NO2		3		3		3			
M533 FRB	PFAS - FRB	533, P, 250mL, C2H7NO2			2		2		2		
M537.1	PFAS	537.1, P, 250 mL, TRZ									
M537.1 FRB	PFAS - FRB	537.1, P, 250 mL, TRZ									